



GANGTOK FIRE STATION
SIKKIM FIRE & EMERGENCY SERVICE
Phone: 03592 202001



No.05/POL/GTK F.S/SF&ES/2024/318

Date: 12.08.2026

PROVISIONAL NO OBJECTION CERTIFICATE

This is to certify that a Provisional No Objection Certificate (NOC) is hereby granted to:

Applicant: Principal

Business/Occupancy: Delhi Public School, Gangtok

Address: Lumsey, Tadong, Gangtok

Total Built Up area: 5739.46 m² (approx)

Occupancy Classification: Educational Buildings (Group B-1)


Height: 19.8 meters (approx)

Fire Safety Recommendations (NBC 2016, Part 4):

- Fire extinguishers (IS 2190:2024 compliant).
- First aid hose reels on each floor, connected to down comer.
- Automatic sprinkler system throughout.
- Fire alarm system: Manually operated electronic fire alarm system
- Terrace tank – 25,000 L with a electric pump of 900 LPM.
- **Note:** All fire protection systems shall conform to relevant IS standards (BIS).

This provisional NOC is valid for **06 months**; Final NOC will be issued upon inspection and compliance.

Issued By:


Fire Station Officer



Gangtok Fire Station

Bishal Rai
Fire Station Officer
SAD, POL, FS